



SRI VIJAYA VISAKHA MILK PRODUCERS COMPANY LIMITED
(VISAKHA DAIRY) CIN No: U15209AP2006PTC048708
Akkireddypalem, BHPV (Post), Visakhapatnam-530012, Andhra Pradesh
GST No.: 37AAJCS7398P1Z4
www.visakhadairy.co.in

To,
Dear Sir / Madam,
M/S.
0
District:
State: ANDHRA PRADESH
Contact: 0
Email: 0
GST No.: NA

We are writing to inquire about the availability and pricing of the following item(s) for our upcoming procurement requirements:

S.No	Description of Items	UOM	Req. Qty	Delivery Location
1	Water Softener Water Softener – 10 KL Capacity : CPMEPM1496 • Type: FRP Filament-Wound Water Softener • Vessel Construction: FRP, Filament-Wound • Treated Water Capacity: 10 KL per regeneration cycle • Raw Water Hardness: Approximately 500 ppm as CaCO₃ • Treated Water Hardness: Maximum 30 ppm as CaCO₃ (preferably) • Resin Type: Strong Acid Cation (SAC) Exchange Resin • Resin Grade: Resin 225 Na • Resin Quantity: 100 Litres • Resin Make: Ion Exchange • Control Valve: Manual Multiport Control Valve • Brine Tank Capacity: 200 Litres • Regeneration System: Manual Regeneration System • Piping Arrangement: Inlet / Outlet / Bypass • Pressure Gauges: Provided • Sampling Points: Provided • Accessories: Complete with all necessary accessories • Application: Softened water suitable for Hot Water Generator (HWG) operation • Scope: Supply, Installation and Commissioning of the complete water softener system. Make: - <i>Pentair/TATA</i> Specifications : • Type: FRP Filament-Wound Water Softener • Vessel Construction: FRP, Filament-Wound • Treated Water Capacity: 10 KL per regeneration cycle • Raw Water Hardness: Approximately 500 ppm as CaCO₃ • Treated Water Hardness: Maximum 30 ppm as CaCO₃ (preferably) • Resin Type: Strong Acid Cation (SAC) Exchange Resin • Resin Grade: Resin 225 Na • Resin Quantity: 100 Litres • Resin Make: Ion Exchange • Control Valve: Manual Multiport Control Valve • Brine Tank Capacity: 200 Litres • Regeneration System: Manual Regeneration System • Piping Arrangement: Inlet / Outlet / Bypass • Pressure Gauges: Provided • Sampling Points: Provided • Accessories: Complete with all necessary accessories • Application: Softened water suitable for Hot Water Generator (HWG) operation • Scope: Supply, Installation and Commissioning of the complete water softener system.	Nos.	3.000	Visakha Dairy (Chittoor Unit) Field Operations

Bidding Opening (Date & Time): 21-09-2026 11:09

Bidding Closing (Date & Time): 26-09-2026 11:09

Kindly provide us with the following information at your earliest convenience:

1. Best quoted price (including taxes and delivery charges)
2. Delivery schedule and terms
3. Payment terms and conditions
4. Warranty/guarantee details (if applicable)
5. Product catalog or brochure (if available)

We are looking forward to building a long-term business relationship and would appreciate your prompt response.

Thank you.

Yours sincerely,
B.V.KONDALA RAO
Designation: Sr. Manager(Purchase)